CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1273:107 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Digital Security Control, 95 Bridgeland, Toronto, Ontario, Canada M6A 1Y7*

Contact: Dan Nita (905) 760-3000 FAX (905) 760-3020

DESIGN: Model PC5010, PC5015, PC5100, P5100, P832 and P832DL combination household fire

and burglary alarm control unit. Refer to listee's data sheet for additional detailed product

description and operational considerations. System components:

PC5010,PC5015,P832,P832DL,PC5100, P5100 Control Unit

PC5132-RS, PC5132-900, P5132-RS Receiver Expansion Board

PC5108, PC5208, P5108, P5208 Expansion Board

KP5508/5516/5532 Keypad PC5508/5508Z/5516/5532 Keypad P832-08/16/32 Keypad LCD5500/KPL5500/P832-LCD Keypad LCD5500Z/P832-LCDZ Keypad Keypad

WLS-909 Wireless Key
AMP-702, PAMP-702 Addressable Point Module

PAMP-700, -701, AMP-700, -701 Door Contact

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required

by code.

MARKING: Listee's name (DSC) or "Partner", model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control units for use with separately listed compatible

initiating and indicating devices. These control units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal. Refer to

listee's Installation Instructions Manual for details.

NOTE: 1. For household system, *Fire Alarm Verification Feature* (Delay of fire alarm

signal) shall not be used in California.

2. Burglary and other non-fire functions were not examined.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager